- (1) A motor controller that has low-voltage release under paragraph (b) of this section.
- (2) A motor controller for a motor of less than 2 horsepower (1.5 kW).
- (d) *Identification of controllers.* (1) Each motor controller and motor control center must be marked externally with the following information:
- (i) Manufacturer's name or identification.
  - (ii) Voltage.
  - (iii) Number of phases.
  - (iv) Current.
  - (v) kW (Horsepower).
- (vi) Identification of motor being controlled.
  - (vii) Current rating of trip setting.
- (2) Each controller must be provided with heat durable and permanent elementary wiring/schematic diagrams of the controller located on the door interior

[CGD 94-108, 61 FR 28281, June 4, 1996; 61 FR 33045, June 26, 1996, as amended by USCG-2003-16630, 73 FR 65199, Oct. 31, 2008]

## §111.70-5 Heater circuits.

- (a) If an enclosure for a motor, master switch, or other equipment has an electric heater inside the enclosure that is energized from a separate circuit, the heater circuit must be disconnected from its source of potential by a disconnect device independent of the enclosure containing the heater. The heater disconnecting device must be adjacent to the equipment disconnecting device. A fixed sign, warning the operator to open both devices, must be on the enclosure of the equipment disconnect device, except as in paragraph (b) of this section.
- (b) If the location of the enclosure for a motor, master switch, or other equipment for deck machinery is remote from the motor and controller disconnect device, a sign must be fixed to the enclosure if the disconnect arrangement required by paragraph (a) of this section is not used. The sign must warn the operator of the presence of two sources of potential within the enclosure and show the location of the heater circuit disconnect device.
- (c) Electric heaters installed within motor controllers and energized from a separate circuit must be disconnected in the same manner as required by

paragraph (a) of this section or by §111.70–7(d).

[CGD 74–125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94–108, 61 FR 28282, June 4, 1996]

## § 111.70-7 Remote control, interlock, and indicator circuits.

- (a) Overcurrent protection. A conductor of a control, interlock, or indicator circuit of a motor controller must be protected against overcurrent unless:
- (1) The conductor is wholly within the controller enclosure;
- (2) The rating or setting of the branch circuit overcurrent device is not more than 300 percent of the current-carrying capacity of the control, interlock, or indicator circuit conductor;
- (3) There is an overcurrent device in each side of the line that has a rating or setting of not more than 300 percent of the current-carrying capacity of the control, electrical interlock, or indicator circuit conductor, except if under operating conditions there is no appreciable difference in potential between the external conductors, overcurrent protection need only be at the supply of that side of the line; or
- (4) The opening of the control, interlock, or indicator circuit creates a hazard.

NOTE: For overcurrent protection of steering gear control and indicator circuits, see Subpart 111.93 of this chapter.

- (b) Accidental ground. The controller must be designed to prevent an accidental ground in a remote control circuit from causing the stop switches to fail to operate or causing the motor to start.
- (c) Source of potential. The potential for a control, interlock, or indicator circuit must be derived from the load side of the motor and controller disconnect device, except if the control functions require circuits that must be common to two or more controllers, the switching arrangement in paragraph (d) of this section must be met.
- (d) Switching. In the design of a control, interlock, or indicator circuit, all practicable steps must be taken to eliminate all but one source of power in an enclosure. If the control functions make it impracticable to energize